



DEPARTMENT OF BUILDING & SAFETY

2008 NEC Electrical Plans Submittal Requirements

333 North Rancho Drive, Las Vegas NV 89106-3703

Phone: (702) 229-6251 Fax: (702) 382-1240

- A. COMPLETE** Single line diagram to include AIC rating & incoming fault at each OCPD (fault calculations not required).
- B.** Service and load calculations per NEC 220.
- C.** Panel schedules and descriptions of circuits with connected loads, panel ratings, and feeder size.
- D.** All outlets, smoke detectors, equipment and feeders shown on plan with appropriate panel and circuit numbers at devices.
- E.** Show emergency power system, type, and model.
- F.** Show voltage drop calculations for all feeders to sub-panels, panels, area lighting, free standing signs, and air conditioning units.
- G.** Compliance Report to the 2008 Southern Nevada Amendments / IECC required on plans.

As an alternate to providing complete voltage drop calculations, the Design Professional may include the following along with the feeder schedule.

Stamp and/or sign.	The Design professional has performed all required voltage drop calculations and all branch circuits and feeders comply with NEC 210-19(A)(1) FPN No. 4.

As an alternate to providing load calculations when the total added load **DOES NOT EXCEED 2000 VA**, the design professional may include the following with a single line diagram from tenant's panel to main and a panel schedule.

Stamp and/or sign.	The Design professional has performed all required load calculations and verifies that all upstream panels and equipment are not overloaded.

See http://www.lasvegasnevada.gov/LawsCodes/building_code.htm for the IECC Amendments.